

# FIRE PROTECTION SYMBOLS (NFPA 170) APPENDIX D-3

FILE NAME	SYMBOL	DESCRIPTION	FILE NAME	SYMBOL	DESCRIPTION	FILE NAME	SYMBOL	DESCRIPTION
F115		ROOF FAN			<b>UTILITY SHUTOFFS</b> E - ELECTRIC SHUTOFF			FP - FIRE PUMP ROOM
F116		WALL FAN			W - DOMESTIC WATER SHUTOFF			TE - TELEPHONE EQUIPMENT ROOM
F117		DAMPER, FIRE			G - GAS SHUTOFF			BR - BOILER ROOM
F118		DAMPER, SMOKE			LPG - LP-GAS SHUTOFF	F133		ET - ELECTRICAL/ TRANSFORMER ROOM
F119		DAMPER, FIRE/SMOKE			NG - NATURAL GAS SHUTOFF	F134		SEISMIC BRACING
F120		DAMPER, BAROMETRIC			CNG - COMPRESSED NATURAL GAS SHUTOFF			NOT USED
F121		PRESSURIZED STAIRWELL	F129		<b>DETECTION/EXTINGUISHING EQUIPMENT</b> DD - DUCT DETECTOR			
F122		VENTILATION OPENINGS			HD - HEAT DETECTOR			
F123		<b>AGENT STORAGE CONTAINER</b> FO - FOAM HL - HALON CL - CLEAN AGENT DC - DRY CHEMICAL WM - WATER MIST			SD - SMOKE DETECTOR			
F124		AGENT STORAGE CONTAINER CARBON DIOXIDE			FS - FLOW SWITCH (WATER)			
F125		FUSIBLE LINK	F130		PS - MANUAL PULL STATION			
F126		FUSIBLE LINK W/ ELECTROTHERMAL FEATURE	F131		TS - TAMPER SWITCH			
F127		SOLENOID VALVE			HL - HALON SYSTEM			
F128		<b>ACCESS FEATURES</b> FD - FIRE DEPARTMENT ACCESS POINT K - FIRE DEPARTMENT KEY BOX RA - ROOF ACCESS <b>ASSESSMENT FEATURES</b> AP - FIRE ALARM ANNUNCIATOR PANEL RP - FIRE ALARM RESET PANEL CP - FIRE ALARM VOICE COMMUNICATION PANEL SP - SMOKE CONTROL & PRESSURIZATION PANEL WB - SPRINKLER SYSTEM WATER FLOW BELL <b>VENTILATION FEATURES</b> SL - SKYLIGHT SV - SMOKE VENT			DC - DRY CHEMICAL WC - WET CHEMICAL SYSTEM FO - FOAM SYSTEM CA - CLEAN AGENT SYSTEM BSD - BEAM SMOKE DETECTOR			
			F132		<b>EQUIPMENT ROOMS</b> AG - AIR-CONDITIONING EQUIPMENT ROOM EE - ELEVATOR EQUIPMENT ROOM EG - EMERGENCY GENERATOR ROOM			